

MONTECITO GROUNDWATER SUSTAINABILITY AGENCY

March 12, 2021

ADDENDUM NO. 4

TO REQUEST FOR PROPOSALS

Groundwater Well Inspection and Equipment Installation Services

DATED March 1, 2021

Notice is hereby given to bidders that this addendum is issued to make changes to the request for proposal document. The following changes shall be made:

ADDENDUM 4

- Task 1:
 - No well modifications should be included in the Proposer's scope of work for this task. Any recommended well modifications identified by the contractor after the initial site visits will be itemized with estimated costs and provided to the Agency prior to conducting Task 1 (b). The Agency will review any Contractor recommendations and determine if additional modifications should be added to the scope of Task 1.
 - No pump modifications should be included in the Proposer's scope of work for this task. Any additional pump modifications identified by the contractor post Task (b) will be itemized with estimated costs and provided to the Agency prior to conducting Task 1 (c). The Agency will review any Contractor recommendations and determine if additional modifications should be added to the scope of Task 1.
 - Proposer shall include any additional costs associated with materials and services for installation of 1" PVC sounding tubes in wells 2, 3, and 4. Tubes shall be designed with capped bottom ends and perforations below water level (well dependent). Any additional associated costs with the installation of these tubes shall be included in Task 1 (a).
 - Proposer shall include costs associated with waste water storage and disposal of any groundwater extracted during reinstallation and testing of the pumps for Tasks 1 and 2.
 - Proposer shall assume standard operating procedures for testing submersible pumps, and the testing of groundwater prior to reconnecting wells to existing water systems. Contractors should be aware that groundwater from wells 1 and 2 is used for potable applications.
 - For Task 1, Proposer must have at least one staff member on site with at least a California State Water Board Distribution Operator D1 certification.

APPROVED:

ADDENDUM 4: GROUNDWATER WELL INSPECTION AND EQUIPMENT INSTALLATION SERVICES

A handwritten signature in black ink, appearing to read 'N. Kunstek', written in a cursive style.

Nicholas Kunstek
Groundwater Specialist